

# CERTIFICATE OF CONFORMITY

This Certificate is issued to

**FIRE ARMOUR PTE LTD**  
**14 Fan Yoong Road**  
**Singapore 629791**

**For Product Certification Scheme: Type 5**

**Product** : Fire Extinguishing System for Kitchen Hood  
**Brand** : LVT  
**Model** : WCK6, WCK9, WCK16, WCK20, WCK26  
**Country of Origin** : Assembly in Singapore  
**Product Details** : A stored pressure extinguishing system that discharge wet chemical solution from fixed nozzles for the extinguishment of fires.  
Capacity: 6L, 9L, 16L, 20L & 26L  
Temperature: +32°F to +120°F

which has complied with the requirements of the scheme based on the following:

<b>STANDARD(S)</b>	<b>TEST REPORT(S)</b>
UL 300: 2019	UL File No.: 15622



**Dixon Ng (Mr)**  
Program Manager  
SETSCO Services Pte Ltd  
18 Teban Gardens Crescent  
Singapore 608925

<i>Certificate No</i>	<i>Date of Issue</i>	<i>Date of Last Revision</i>	<i>Date of Expiry</i>
FSP-2013-0149	10/10/2019	30/06/2020	17/09/2024



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at [www.setsco.com](http://www.setsco.com)