

CERTIFICATE OF CONFORMITY

This Certificate is issued to

FIRE ARMOUR PTE LTD
14 Fan Yoon Road
Singapore 629791

For Product Certification Scheme: Type 5

Product : Fire Extinguisher
Brand : HERCULES
Model : Refer to Appendix
Country of Origin : Singapore
Product Details : Dry powder type of fire extinguisher.
Refer to Appendix for fire rating.

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
SS EN 3-7: 2012	SETSCO Test Report No.: MM-8500061611/CCH
BS EN 3-8: 2006	Refer to Appendix



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2019-0866

Date of Issue
01/08/2019

Date of Expiry
31/07/2024



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com



Model	Product Description	Fire Rating	Test Report
FT01-01A-00	1kg Dry powder fire extinguisher, stored pressure	8A, 34B	BSI Test Report No.: 8505046-1 Issue 3 TUV Rheinland Report No.: FT01-01A-00D1
FT01-02A-00	2kg Dry powder fire extinguisher, stored pressure	13A, 55B	BSI Test Report No.: 8505046-2 Issue 3 TUV Rheinland Report No.: FT01-02A-00C2
FT01-03A-00	3kg Dry powder fire extinguisher, stored pressure	21A, 70B	BSI Test Report No.: 8505046-3 Issue 3 TUV Rheinland Report No.: FT01-03A-00A1
FT01-04A-00	4kg Dry powder fire extinguisher, stored pressure	27A, 113B	BSI Test Report No.: 8505046-4 Issue 3 TUV Rheinland Report No.: FT01-04-00A
FT01-06A-00	6kg Dry powder fire extinguisher, stored pressure	34A, 183B	BSI Test Report No.: 2400/8248351 Model FT01-06A-00 TUV Rheinland Report No.: FT01-06A-00C
FT01-09A-00	9kg Dry powder fire extinguisher, stored pressure	43A, 183B	BSI Test Report No.: 8505046-6 Issue 3 TUV Rheinland Report No.: FT01-09A-00C
FT01-12A-00	12kg Dry powder fire extinguisher, stored pressure	55A, 233B	BSI Test Report No.: 8505046-7 Issue 3 TUV Rheinland Report No.: FT01-12A-00B

Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2019-0866

Date of Issue
01/08/2019

Date of Expiry
31/07/2024

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.