

CERTIFICATE OF CONFORMITY

This Certificate is issued to
FIRE ARMOUR PTE LTD
14 Fan Yoong Road
Singapore 629791

For Product Certification Scheme: Type 5

Product : Fire Extinguisher
Brand : HERCULES
Model : FT01-09A-00/CE1 & FT01-06A(Rev 4)-00
Country of Origin : Singapore

Product Details :

Model	Product Details	Fire Rating
FT01-09A-00/CE1	9 Litre AFFF Foam Fire Extinguisher, Stored Pressure	21A 233B
FT01-06A(Rev 4)-00	6 Litre Wet Chemical Fire Extinguisher, Stored Pressurer	13A 75F

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS EN 3-7: 2012
BS EN 3-8: 2006

TEST REPORT(S)

SETSCO Test Report No.: MM-8500068904/CCH
BSI Test Report No.: 2244/8197011 FT01-06A(Rev4)-00
TUV Rheinland Report No.: FT01-06A(Rev4)-00/CE5
BSI Test Report No.: 2244/7685896 Model FT01-09A-00CE1 Issue 2
TUV Rheinland Report No.: FT-09A-00/CE5



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No

FSP-2019-0879

Date of Issue

30/09/2019

Date of Expiry

29/09/2024



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com