

CERTIFICATE OF CONFORMITY

This Certificate is issued to

FIRE ARMOUR PTE LTD
No. 14 Fan Yoong Road
Singapore 629791

For Product Certification Scheme: Type 5

Product : Fire Extinguisher
Brand : HERCULES
Model : FT02-02F-00 & FT02-03D-00
Country of Origin : Singapore

Product Details :

Model	Product Description	Fire Rating
FT02-02F-00	2kg carbon dioxide, stored pressure	34B
FT02-03D-00	5kg carbon dioxide, stored pressure, letter horn	89B

which has complied with the requirements of the scheme based on the following:

STANDARD(S)

SS EN 3-7: 2012
SS EN 3-9: 2006

TEST REPORT(S)

BSI Test Report No.: 2244/7685896 Model FT02-02F-00
BSI Test Report No.: 2244/7685896 Model FT02-03D-00
SETSCO Test Report No.: MM-8500080859-CCH
TUV Rheinland IR No.: 154308467-8
TUV Rheinland IR No.: 154308467-9



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2019-0896

Date of Issue
8/11/2019

Date of Expiry
13/06/2024



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is governed by SETSCO's Terms and Conditions for Certification. The certified client is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking SETSCO website at www.setsco.com