

CERTIFICATE OF CONFORMITY

This Certificate is issued to

FIRE ARMOUR PTE LTD

(UEN No.: 198203978C)

14 Fan Yoong Road, Singapore 629791

For Product Certification Scheme: Type 5

Product : Mobile Fire Extinguisher

Brand : HERCULES

**Model : FT03-042B-00, FT03-047C-00, FT03-047D-00,
FT03-042D-00, FT03-047F-00, FT03-047G-00**

Country of Origin : Singapore

**Product Details : Dry Powder Mobile Fire Extinguisher
AFFF Foam Mobile Fire Extinguisher
Refer to Appendix for details.**

which has complied with the requirements of the scheme based on the following:


STANDARD(S)

BS EN 1866-1: 2007

TEST REPORT(S)

BSI Test Report No.: 2244/8345354-3 FT03-042D-00
BSI Test Report No.: 2244/8345354-2 FT03-047C-00
BSI Test Report No.: 2244/8345354-4 FT03-047F-00
BSI Test Report No.: 2244/8345354-6 FT03-047G-00
BSI Test Report No.: 2244/8345354-5 FT03-047D-00
BSI Test Report No.: 2244/8345354-1 FT03-042B-00

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No
BCM-2018-0048

Date of Issue
09/06/2023

Date of Expiry
12/07/2026

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

Model	Product Details
FT03-042B-00	25 Kg ABC powder, stored pressure
FT03-047C-00	50Kg ABC powder, stored pressure
FT03-047D-00	50 Litre AFFF foam, stored pressure
FT03-042D-00	25 kg ABC powder, 1.34 kg CO2 cartridge
FT03-047F-00	50 Kg ABC powder, 1.6kg CO2 cartridge
FT03-047G-00	50 Litre AFFF foam, 1.6kg CO2 cartridge



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No
BCM-2018-0048

Date of Issue
09/06/2023

Date of Expiry
12/07/2026

Amendments or additions to this appendix other than those authorized by SETSCO render the appendix invalid.